



SECTION B
NTS 714

NOTES:

1. PIVs AND FDCs SHALL BE LOCATED AT LEAST 40 FEET FROM BUILDINGS WHERE SITE CONDITIONS ALLOW. WALL MOUNTED PIV'S AND FDC'S MAY BE USED WHEN APPROVED BY THE FIRE CODE OFFICIAL.
2. FDC CONNECTION SHOWN IS FOR A FOUR WAY SYSTEM. OTHER CONFIGURATIONS ARE ALLOWED. REFER TO APPROVED FIRE SYSTEM DRAWINGS FOR FDC SIZE AND TYPE.

Todd Short

APPROVED BY: TODD SHORT
ASSISTANT FIRE MARSHAL

REVISION DATE: MARCH 01, 2016



STANDARD DETAILS

FIRE SPRINKLER SYSTEM
BACKFLOW PREVENTER

FILE NAME: SD714.DWG

DETAIL NUMBER: 714A